


Description

IP65. Surface mounted wallwasher. Suitable for installation over 4" recessed junction box in uplight or downlight position. Optional 2200 K version available. To be specified at time of ordering.

Weight	14.60 lb	
Light distribution	symmetric, medium beam [M]	
Light source	LED-12/18W / 500 mA - 2700 K	
CRI	80	
Power supply	electronic gear	
BUG	B2 U0 G0	
LEDs	12	
Rated input power	21 W	
Nominal Lumen (lm)		
LED Lumen	200	
Total Lumen	2400	
Tj	85	
Delivered lumens (lm)		
LED Lumen	172.3	
Total Lumen	2068	
Та	25	



Specifications Material description

Body	Luminaire body and lens frame constructed in die cast aluminum.		
Lens	Tempered glass lens.		
Colors	RAL9004 Black		
	RAL9007 Grey Metallic		
	RAL9016 White		
	RAL8019 Dark Bronze		
Gasket	Silicone rubber gasket		
Fasteners	PCS polymer coated stainless steel		
Ingress protection	IP65		
Impact resistance	IK07		
Corrosion resistance	5CE		

Electrical description

Power supply	Integral [ECG] electronic driver 120V-277V. 0-10V dimmable, to be specified with order.
Driver / Ballast	Integral EC electronic converter

WE-EF LIGHTING USA, LLC

410-D Keystone Drive, 15086 Warrendale, PA 15086 - Phone: +1 724 742 0030 customersupport.usa@we-ef.com - https://we-ef.com/us Subject to technical changes and errors. - Generated on 08/16/2025

132-0634

OLV330 LED



Additional information

Lifetime	Ta=25°/40° L90B10 > 90000h
BUG Rating	Please see individual Spec Sheets for classification of Backlight, Uplight and Glare.
Listings	ETL listed. Suitable for wet locations.


WE-EF LIGHTING USA, LLC 410-D Keystone Drive, 15086 Warrendale, PA 15086 - Phone: +1 724 742 0030 customersupport.usa@we-ef.com - https://we-ef.com/us Subject to technical changes and errors. - Generated on 08/16/2025

132-0634

OLV330 LED

Mounting Accessories

Surface Collar



we-ef

Electrical Accessories

Emergency Lighting Package

Description	Part ID	Additional information
OLV33_ LED Emergency Lighting Package	132-6900	Emergency battery backup operating for a minimum of 90 minutes, at full power, when main power is lost.