## **QRI354 LED**





## **Description**


IP66, Class I. IK08. Marine-grade, die-cast aluminium alloy. 5CE superior corrosion protection + primer including PCS hardware. Silicone rubber gasket. Safety glass lens. Two cable entries.

A pre-installation blockout is available and recommended for mounting in concrete walls.

Weight	3.40 kg
Light distribution	asymmetric, forward throw [A60]
Light source	LED-12W / 350 mA - 3000 K
CRI	80
Power supply	EC
LEDs	1
Rated input power	15 W
Rated lumens (lm)	
LED Lumen	511.9
Total Lumen	511.9
Та	25
Nominal Lumen (lm)	
LED Lumen	2140
Total Lumen	2140
Тс	25

## **QRI354 LED**





# **Specifications Material description**

Body	Marine-o	grade, die-cast	aluminium all	ΟV
Doug	iviaiiiie-u	grade, die-casi	. aiuiiiiiiiiuiii aii	U

Lens Safety glass lens

Colours RAL9004 Signal black

RAL9006 White aluminium
RAL9007 Grey aluminium

Gasket Silicone rubber gasket

Fasteners PCS Polymer Coated Stainless Steel Hardware

Ingress protection IP66
Impact resistance IK08

Corrosion resistance 5CE+Primer

## **Electrical description**

Driver / Ballast Integral EC electronic converter

## **Additional information**

#### WE-EF LIGHTING Pty Ltd


## **QRI354 LED**




# **Mounting Accessories**

## **Installation blockout**

Description	Part ID	Α	В	C1	С					
Installation blockout BQR35-I	197-0129	272	272	125	125					



Installation blockout BQR35-II 197-0132 272 272 150 150



## 197-9084

## **QRI354 LED**



## **Control**

# 1-10 V analogue dimming interface

Description	Part ID	С
1-10 V analogue dimm	e 430-0011	90

## 197-9084

## **QRI354 LED**



## **DALI** interface

Description	Part ID	Additional information	С
DALI interface	430-0013	DALI variant. The luminaire is equipped with a DT6 Dali driver (Dali 2.0).	90
		Dali 2.0 -Application controllers and Input devices defined -Single-masters and multi-masters allowed -Event priorities defined -Separate addressing & grouping from control gear	
		Note: Mixing Dali 1 and Dali 2.0 drivers can cause problems because the addressin and the command scope has changed!	g